

Contact person	Date	Reference	Page
Richard Johansson Safety +46 10 516 56 75 richard.johansson@ri.se	2021-03-12	137618-1	1 (4)

Exolon Group NV
Wakkensesteenweg 47
BE-8700 TIELT
Belgien

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to the products “Exolon UV clear 2099”, “Exolon ClimateControl UV green 2655” and “Exolon UV white 2150” in accordance with the procedure given in EN 13501-1:2018.

This classification report replace RISE classification report P902844Arev5, dated January 27, 2020. The names of the products have been changed.

2 Details of classified product

2.1 General

The products “Exolon UV clear 2099”, “Exolon ClimateControl UV green 2655” and “Exolon UV white 2150” are defined as polycarbonate sheets. Their classification is valid for the following end use applications:

Wall claddings, walls, ceilings, window panes, advertisement, roofs, light domes, light covers and design.

According to the owner of this classification report, this product complies with the European product specification EN 16240:2013.

2.2 Product description

According to the client:

Clear transparent sheet called “Exolon UV clear 2099” consisting of 100 % polycarbonate, foreseen with UV protection coex layer with polycarbonate as basis. The product has a nominal density of 1200 kg/m³ and a nominal thickness of 1 to 6 mm.

Green tinted transparent sheet called “Exolon ClimateControl UV green 2655” consisting of 95 % polycarbonate and about 5 % masterbatch to get green tint, foreseen with UV protection coex layer with polycarbonate as basis. The product has a nominal density of 1200 kg/m³ and a nominal thickness of 1 to 6 mm.

Opal white sheet called “Exolon UV white 2150” consisting of 95 % polycarbonate and about 5 % white masterbatch, foreseen with UV protection coex layer with polycarbonate as basis. The product has a nominal density of 1200 kg/m³ and a nominal thickness of 1 to 3 mm.

RISE Research Institutes of Sweden AB

Postal address	Office location	Phone / Fax / E-mail
Box 857 SE-501 15 BORÅS Sweden	Brinellgatan 4 SE-504 62 BORÅS	+46 10 516 50 00 +46 33 13 55 02 info@ri.se

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of RISE.



3 Test reports, extended application reports & test results in support of classification

3.1 Test reports and extended application reports

This classification is based on the test reports listed below:

Name of laboratory	Name of sponsor	Test report reference no	Accredited test methods and date
SP	Covestro (Tielt) NV	P902844	EN 13823:2010+A1:2014 and EN ISO 11925-2:2010/AC:2011
WFRGENT N.V. Ghent, Belgium	Covestro (Tielt) NV	11748E	EXAP report in accordance with CEN/TS 15117

3.2 Test results

The test results listed below show the worst case as found in the test programme performed and reported according to the table above. The tests have been carried out on products covering the thickness range of the product group. The “Guidance on direct and extended application” CEN/TS 15117 has been applied in the process of selecting suitable products for testing.

Test method	Parameter	Number of tests	Results	
			Continuous parameter mean (m)	Compliance with parameters
EN ISO 11925-2		8		
Surface flame attack*				
30 s exposure	$F_s \leq 150$ mm		(-)	Compliant
Flaming droplets/particles	Ignition of filter paper		(-)	No ignition of filter paper
EN 13823		10		
	$FIGRA_{0,2MJ}$ (W/s)		33	Compliant
	$LFS < edge$		(-)	Compliant
	THR_{600s} , (MJ)		1.7	Compliant
	$SMOGRA$, (m ² /s ²)		6	Compliant
	TSP_{600s} , (m ²)		49	Compliant
	Flaming droplets/particles		(-)	No flaming droplets/particles

* : as required to the end use application of the product

(-) : not applicable

4 Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 11 and 15 of EN 13501-1:2018.

4.2 Classification

The products called “Exolon UV clear 2099”, “Exolon ClimateControl UV green 2655” and “Exolon UV white 2150” in relation to their reaction to fire behaviour are classified:

B

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming particles/droplets is:

d0

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation product is:

Fire Behaviour		Smoke Production				Flaming Droplets	
B	-	s	1	,	d	0	

Reaction to fire classification: *B-s1,d0*

4.3 Field of application:

This classification is valid for the following product parameters:

- Nominal thickness: 1 - 6 mm for “Exolon UV clear 2099” and “Exolon ClimateControl UV green 2655”.
- Nominal thickness: 1 - 3 mm for “Exolon UV white 2150”.
- Nominal density: 1200 kg/m³.
- Colour: Transparent clear, transparent green and white.

This classification is valid for the following end use conditions:

- Freestanding with the edges protected by a metal frame.

5 Limitations

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of performance by the manufacturer within the context of system 3 of assessment and verification of constancy of performance and CE marking under Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR). The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested.

RISE Research Institutes of Sweden AB Safety - Fire Research, Fire Dynamics

Performed by

Examined by

Richard Johansson

Per Thureson